



## SOLAR PANEL EXCEPTION GUIDELINES

Some roofs of commercial structures will be considered for waiving the workspace requirements for panel installation.

The following checklist must be completed first:

- Structure is fire sprinklered per NFPA 13 and has received annual servicing for the sprinkler system within the last year
- No other equipment is on the roof space under consideration
- A sign shall be posted by the main electrical shut-off and at the fire department connection (FDC) stating, "No fire department access on solar panel roof". Letters shall be no less than 2" height and on contrasting weather-resistant materials

With the above noted, project shall be submitted to Fire Marshal for review and approval.